

## Consultative Meeting Notification 96/2017

**Buyer-Seller Consultation on Distribution or Control  
Board Enclosures (Distribution board for MCBs) dated  
29.11.2017**

Presented by :

Date :



Consultative Meeting Notification 96 / 2017

**Buyer-Seller consultation on Distribution or control board enclosures ( Distribution board for MCBs) dated 29.11.2017**

Consultative Meeting held on 29<sup>th</sup> November 2017 for Distribution **or control board enclosures (Distribution board for MCBs)** with Sellers and buyers. Following participated in the meeting.

**Sellers participants:**

- i) M/s. Adhunik Switchgear (P) Ltd.
- ii) M/s. Sainico Industries
- iii) M/s. Bajaj Electrical Ltd.
- iv) M/s. K.D. Enterprises
- v) M/s. Novatek Electro India (P) Ltd.
- vi) M/s. Electro Control Panels
- vii) M/s. Mamta Products
- viii) M/s. Kirpal Electricals
- ix) M/s. Bentex Control Switchgear Co.
- x) M/s. Synergic Systems, Ghaziabad
- xi) M/s. Gupta Bakelite Factory, Delhi
- xii) M/s. Balaji Traders
- xiii) M/s. Al. V. Enterprises

**Buyer participants:**

- i) NTRO (PMO)
- ii) NIA (MHA) GOI

1. Following **Golden parameters** were decided based on the suggestions and discussions :

- i) Suitable to accommodate specified Number of poles (number)
- ii) Ways(poles) (number)
- iii) Metallic cover Type
- iv) Minimum Sheet Thickness properly pretreated and stove enameled/Powder Coated (mm)
- v) Enclosure category (Degree of Protection)

2. Changes were decided based on the suggestions and discussions.

Sl.No.	Parameter	Changes Suggested and finalized during Consultative meeting
1	Ways(poles) (number) 4, 8, 12, 24, 36	Parameter to be modified as No. Of ways instead of existing one. Further 6, 10, 16, 18 also to be added.
2	Metallic cover Type – (MCB are operable without opening cover, MCBs accessible only after opening of top cover)	<b>To be modify as</b> MCB are operable without opening cover ( <b>Single door</b> ), MCBs accessible only after opening of top cover ( <b>Double door</b> )



4	Enclosure category (Degree of Protection)	<b>IP 43 also to be added</b>
---	---	-------------------------------

**New Category suggested**

Separate category shall be created for pre wired distribution boards for MCB and MCCBs.

It was decided that the above suggestion may be uploaded on forum for further feedback.

Regards

GeM-Admin