

Consultative Meeting Notification 108/2017

Buyer-Seller Consultation on Solar Street Lighting and Renewable Energy Street Lighting dated 15.12.2017

Presented by :

Date :



Buyer-seller consultation on Solar street lighting and renewable energy street lighting dated 15.12.2017

Meeting held on 15th December 2017 for Solar street lighting and renewable energy street lighting items with sellers and buyers.

Seller's participants:

- M/s. Sar Green Energies
- M/s. Sahai Solar (P) Ltd.,
- M/s. Orbit Industries
- M/s. Saiap Ltd.,
- M/s. Aska Equipments Ltd.,
- M/s. Sukhwel Industries (P) Ltd.,
- M/s. Eltech Enterprises
- M/s. Medihelp Health care (P) Ltd.,
- M/s. Digital India Security Products Pvt., Ltd.,
- M/s. Security defence system
- M/s. Sundak Sales Solutions
- M/s. Master controls
- M/s. Mini tech systems
- M/s. Static Systems
- M/s. Bajaj Electricals Ltd.,

Buyer participants:

- 220 BN CRPF, Dy., Commandant, Delhi
- Assam Rifles
-

Following **Golden parameters** were decided based on the suggestions and discussions:-

- Model as per MNRE Specification
- Battery
- PV module (Wp) under STC (Wp)
- Battery capacity (12V-AH @ C/10)
- Scope of supply

■ Changes were decided based on the suggestions and discussions:-

Parameter	Changes Suggested and finalized during Consultative Meeting
■ Type of Light source – White LED	White LED shall be Max. 7W as per MNRE specification
■ Colour temperature of White - LED (deg K) – Must Declare	Value shall be 5500 deg. K to 6500 deg. K



■ No load current consumption (mA) – Must declare	Value shall be ≤ 20 mA
■ Warranty for street lighting system including battery (Years)	Value shall be ≥ 5 Years
■ Warranty for Pv module (Years)	Value shall be ≥ 25 years
■ Solar Photo voltaic Systems, Devices and Components shall meet and comply with Compulsory Registration Scheme of BIS as applicable	Option shall be : Yes , Not applicable at present

Suggestion from Buyer:

Suggestion from Buyer and Seller : All the test reports and certificates shall be uploaded on GeM portal by the seller and available on line / on Web site for buyer's verification.

New Parameter suggestion:

(1) Housing material of street light fitting shall be Polycarbonate, Plastic FRP, Aluminium, MS Galvanized

Regards

GeM-Admin
